

-		F WEST GROVE OF OCCUPANCY INSPEC	TION LICT
			TION LIST
PROPERTY ADDRESS:		DATE:	*
TAX PARCEL #:**APPLICA	NT MUST SPECIE	PRESENT USE OF PRO	OPERTY**
7	EXT	TERIOR	
	APPROVED	NOT APPROVED	COMMENTS
4 10/611/19 01/19/60	AFFROVED	NOTAPPROVED	COMMENTS
1. Walking surface			
to public right-of-way 2. Handrails/stairs in			
good condition. 3. Grass trimmed under			
6 inches.			
4. House numbers installed			
(must be visible from			
the street).			
5. Electric (receptacles must			
comply with applicable			
electrical code.			
ologital sous.	INT	ERIOR	
	APPROVED	NOT APPROVED	COMMENTS
Sump Pump piped to outside	711110120	NOTAL TROVES	O MINICIAL O
(not connected to sewer			
system).			
2. Furnaces:			
Heater in working condition.			
All furnances must have			
emergency switch at			
stairway entrance.			
Smoke dectectors working.			
One on each floor.			
One in each bedroom.			
4. Hot water blow off valve piped			
8-10" from floor.			
5. GFI outlets in kitchen and	•		
bathroom.			
Electrical pan circuit breakers			
identified.			
6. Doors and locks must be			
operable.			
7. Windows in good condition.			
8. Stairs (see item #2 -	,		
exterior above)			
9. Electrical Underwriter			
Certification on new			
installation.			
10. Carbon Monoxide Alarm:			
outside sleeping area within			
dwelling with attached			
garage and/or fuel-fired			
appliances and basement.			
		·	
OWNER:		INSPECTOR:	